

This checklist is based on Building Regulations ADJ Appendix A, using *standard* Dunbrik gas flue data. The builder/installer should insert details of the actual fireplace opening sizes, actual ventilation installed and any variations to the usual data.

<b>ADJ Checklist for Hearths, fireplaces, flues and chimneys</b>	
<p>This checklist can help you to ensure hearths, fireplace, flues and chimneys are satisfactory. If you have been directly engaged, copies should also be offered to the client and to the Building control body to show what you have done to comply with the requirements of part J. If you are a sub-contractor, a copy should be offered to the main contractor.</p>	
<p>1. Building address, where work has been carried out:</p> <p>_____</p>	
<b>ADJ appendix A</b>	<b>Details to amend or complete</b>
2. Identification of hearth, fireplace, chimney or flue	<i>Fireplace in Lounge</i>
3. Firing capability	<i>Gas only</i>
4. Intended type of appliance. State type or make. If open fire give finished fireplace opening dimensions.	<i>Gas fire - radiant/convector up to 7kW heat input suitable for installation into gas flue block system to BSEN1858 or BS1289</i>
5. Ventilation provisions for the appliance. State type and area of permanently open air vents	<i>Additional ventilation not required</i>
6. Chimney or flue construction	
a) State the type or make and whether new or existing	<i>New. Gas flue blocks to BSEN1858</i>
b) Internal flue size (and equivalent height, where calculated - natural draught gas appliances only)	<i>185mm x 90mm Equivalent flue height = _____</i>
c) If liners used confirm they are correctly jointed in accordance with manufacturers instructions and state jointing materials used.	<i>Tongue upwards into rebate and jointed with Dunbrik 1581 silicone sealant</i>
d) If an existing chimney has been refurbished with a new liner, type or make of liner fitted	<i>Not Applicable</i>
e) Details of flue outlet terminal Outlet detail: Complies with:	_____ _____
f) Number and angle of bends	_____ <i>lateral offsets at 30 degrees</i>
g) Provision for cleaning and recommended frequency	<i>Annual service by Gas Safe Registered Engineer</i>
7. Hearth. Form of construction. New or existing	
8. Inspection and testing after completion Tests in Appendix E of AD J 2010	Tests carried out by:
Flue Inspection results:	_____
Visual	Sweeping not applicable
Sweeping	Coring ball not applicable
Coring ball	_____
Smoke	
Spillage	
Appliance (where included)	
<p><b>I/We the undersigned confirm that the above details are correct. In my opinion, these works comply with the relevant requirements in Part J of Schedule 1 to the Building Regulations.</b></p>	
Print name and title _____	Profession _____
Capacity _____	Tel No. _____
Address _____	Postcode _____
Signed _____	Date _____
Registered membership of (e.g. Gas Safe, OFTEC, HETAS, NACE, NACS) _____	Reg. _____